

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015841  
DATE: 08/10/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: EOSS System  
CODE: 2965-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>EOSS System Doors and Windows (Shandong) Co., Ltd. 7027 Dongtai Road, Dongcheng Street Weifang, Shandong, China 262600</b>	<b>Series "ES70 System" Aluminum Awning Window</b>  Configuration: X Glazing: Insulating Glass (Tempered)  Frame: W•1200mm(47.24") H•1000mm(39.37") Sash: W•1083mm(42.65") H•883mm(34.78") DLO: W•930mm(36.61") H•730mm(28.74")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/LS.2/A440-17</b>	<b>Class CW-PG40 1200 x 1000 (47 x 39)-AP Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.84 psf)</b>

Product Tested By: Intertek, LLC  
Report No: 211129011 SHF-002  
Expiration Date: July 31, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)